

ADDENDUM NO. 1
TO REQUEST FOR PROPOSALS
FOR

WZ 6MG RESERVOIR SEISMIC RECONSTRUCTION PROJECT - PHASE 1 PDR

The proposer is directed to make the following corrections, deletions, and/or additions to the contract documents heretofore dispensed to proposer for the above project; and to note proposer's receipt of this addendum by number on the addenda acknowledgment form, which shall be submitted with the proposal:

To REQUEST FOR PROPOSALS:

1. In section VI. SCHEDULE, DELETE and REPLACE the Schedule Item as follows:

ITEM

TARGET DATE

Questions Due:
Receive Proposals from Consultants:
Committee Approval:
First Draft (Outline):

Thu, July 10, 2025, 4:00 pm
Thu, July 24, 2025, 4:00 pm
August 2025
October 2025


PRE-PROPOSAL MEETING:

1. Question: Is temporary water storage needed during the project?
Answer: Yes, consultant should include a temporary water storage facility to serve the existing system during construction of the new facility.
2. Question: Does environmental documentation need to be included as part of the PDR efforts?
Answer: No, Phase 1 activities have previously been determined to be Categorically Excluded under Catex Category Code A7.

END OF ADDENDUM No. 1

Addendum approved for issuance:

By:



Bobby Young, Engineering Manager

Date: 06/23/2025